

ASSAM UNIVERSITY: SILCHAR NOTICE INVITING TENDER

Assam University, Silchar, invites sealed tender with a validity period of 180 (One hundred eighty) days from the date of receipt of tender in prescribed format available in the Engineering Section of Assam University, Silchar from the Govt. Registered Electrical contractors of APWD/CPWD/MES/PSU of appropriate class and category having valid registration for the work as mentioned below:-

Name of Work	Estimated Cost	EMD	Time of Completion	Cost of Tender Paper	Last date of submission of Tender	Due date and time for opening of sealed tender Paper
1) Erecting of New LT line for Widening of the Campus Main Road & Dismantling of the Existing MS Poles & LT Lines. 2) Extension Admin LT line to Existing Generator Room. 3) Rearrangement of LT line for Health Center, UN Brahma Auditorium & Foreign Hostel to nearest 250 KVA Transformer.	₹ 6,20,056/ -	₹12,500/-	30 (thirty) Days	₹ 500/-	21.12.2017 upto 2.00pm	21.12.2017 at 3.00pm

The eligible Contractor who are financially sound and proficient in the similar nature of works are to quote their rate in item wise basis and rate should be inclusive of all taxes & incidental charges. Self-attested copy of (i) Valid registration certificate (ii) GST Registration (iii) PAN Card (Where PAN of the deducted is not available, Tax at higher of the prescribed rate or 20% will be deducted on all transactions) (iv) Bank Solvency (V) Work experience on similar nature of work duly signed are to be enclosed with the tender without which the tender will not be accepted.

The interested bidder may examine the nature of work available in Engineering Section and visit the site to satisfy themselves about the scope of the work before submitting the tender. The duly filled in tenders can be submitted by hand in the Tender Box at Engineering Section, Administrative Building, Assam University, Silchar on 21.12.2017 upto 2.00pm. Tenders will be opened on 21.12.2017 at 3.00pm in presence of the tenderers or their authorized representatives.

The detail NIT may be obtained from the Engineering Section, Assam University, Silchar on all working days from 14.12.2017 to 21.12.2017 upto 12.00 noon by submitting necessary application fees in Cash at the cash counter of the University and Tender document can also be downloaded from University web site www.aus.ac.in for which non refundable tender fees of Rs 500/- per tender payable in DD (Drawn in favour of Assam University, Silchar) to be enclosed as application fees along with tender document. If the office remains close for any reason, the tender will be received/opened on next working day at same time and place. The contractor will have to pay AGST and other Taxes as per Govt. Notification prevailing in the state.

The University does not bind itself to accept lowest tender and reserves the right to reject any or all the tenders received by recording clear, logical reasons. Canvassing in any form will be a disqualification for submission of the tender including submission of tender to the university in future.

Executive Engineer Date:-13.12.2017

No. AU/ENGG/MAINT/ELECT/151/2017

Copy to:-

- 1. P.S. to V.C. for kind information of the Hon'ble Vice-Chancellor.
- 2. P.S. to Registrar, AUS, for kind information of the Registrar.
- 3.P.S. to Finance Officer, AUS, for kind information of the Finance Officer.
- 4. The Director Computer Centre, AUS, for information & with a request to upload the aforesaid notice in University website
- 5. Notice Board.
- 6. File.

Section Officer (Engg)



Tender for 1) Erecting of New LT line for Widening of the Campus Main Road & Dismantling of the Existing MS Poles & LT Lines. 2) Extension Admin LT line to Existing Generator Room. 3) Rearrangement of LT line for Health Center, UN Brahma Auditorium & Foreign Hostel to nearest 250 KVA Transformer.



ASSAM UNIVERSITY, SILCHAR

(A Central University Established by an Act of Parliament)
Silchar-788011,Assam,India.

Certified that both Technical& Price Bid contains (26) pages including the cover page.



ASSAM UNIVERSITY, SILCHAR

(A Central University Constituted under Act. XXIII of 1989) Silchar – 788011, Assam, India.

File No:-AU/ENGG/MAINT/ELEC-151/2017

NIT/ TENDER PAPER

Date:-13.12.2017

Name of works: - 1) Erecting of New LT line for Widening of the Campus Main Road & Dismantling of the Existing MS Poles & LT Lines. 2) Extension Admin LT line to Existing Generator Room. 3) Rearrangement of LT line for Health Center, UN Brahma Auditorium & Foreign Hostel to nearest 250 KVA Transformer.

• Cost of Tender Paper: Rs.500/-

• Estimated Cost: Rs.6,20,056/-

• Earnest Money: Rs.12,500/-

• Last date of issue of tender paper: 21.12.2017 up to 12 noon.

• Last date of submission of tender paper: 21.12.2017 up to 2 pm.

• Date and Time of Opening Bid: 21.12.2017 at 3 pm.

CONTENTS

❖ SECTION-1 : Notice Inviting Tender & Tender Condition.

❖ SECTION-2 :Proforma Of Submission Of Quotation.

❖ SECTION-3 : General Rules & Direction.

❖ SECTION-4:Terms& Conditions Governing the Tender and Execution of Contract Thereof.



CHECK LIST OF DOCUMENTS

1.	Valid Registration certificate of		
	Central Govt. / State Govt./PSU ,Proforma 2(a)		
	(Xerox copy self-attested)	:	Yes/No

2. PAN CARD (Xerox copy self-attested) : Yes/No

1. Experience certificate:

Experience of executing similar nature works during the last seven years with the record of completion. (Proforma 3(a)

(Xerox copy self attested). : Yes/No

- Bank solvency from nationalized Bank as per prescribed
 Proforma-2(C)(Xerox copy self attested): Yes/No
- On going works statement (Xerox copy self attested)
 proforma 3(b): Yes/No
- 6. GST Registration : Yes/No

Signature of Agency / Contractor



SECTION -1

File No. AU/ENGG/MAINT/ELEC-151/2017

Date:- 13.12.2017

NOTICE INVITING TENDER

Sealed Item rate tenders in two bid system valid for 180 days are invited from Registered Electrical Contractors having valid registration & license of CPWD/MES/State PWD/PSU of appropriate class and category for the works of "1) Erecting of New LT line for Widening of the Campus Main Road & Dismantling of the Existing MS Poles & LT Lines. 2) Extension Admin LT line to Existing Generator Room. 3) Rearrangement of LT line for Health Center, UN Brahma Auditorium & Foreign Hostel to nearest 250 KVA Transformer.

Last Date of submission of bid is 21.12.2017 up to 2 pm.

Sd/-

Executive Engineer



TENDER CONDITIONS:

- 1. The Tenderer shall quote his rate as per NIT & the Terms and Conditions enclosed in the Tender document.
- 2. Tender Documents can be obtained from the Engineering Section of Assam University during working hours against written request and on payment of **Rs.500/- (One hundred fifty only)**either in cash or by demand draft drawn in favour of Assam University, Silchar, payable at Silchar.
- 3. **TheEarnest Money Deposit (EMD) of Rs. 12,500**/-mentioned above is absolutely mandatory and shall be enclosed along with the tender in the form of **Bank Draft/ FDR /Call Deposit drawn in favour of the Assam University, Silchar** from a scheduled /nationalized bank only, failing which the tender will not be accepted.

4. Mode of Submission of tender Document:

- A. EMD to be sealed in Envelop No-1
- B. Technical Bid is to be sealed in Envelop No-2
- C. Price Bid is to be sealed in Envelop No-3
- D. Envelop No-1,2&3 to be inserted in a single Envelop-4, properly sealed and super scribing Name of Work, Closing Date & Name of Agency/Contractor on the cover of the Envelop-4
- E. The tender submitting parties should confirm submission of tenders through email to AUS ID: ps_vc@aus.ac.in
- F. N.B Sealed Means: Sealing by Wax/Gum/Any Type of Adhesive Tape etc. but not pinned or stapled.
- 5. Tenders should be valid for 180 days from the date of opening of the tenders and may have to be extended further if considered necessary by the University. No reasons will be assigned for extension and no withdrawal shall be allowed. If any tenderer withdraws his tender before the said period or issue of letter of acceptance, which-ever is earlier, or makes any modifications in the terms and conditions of the tender which are not acceptable to the University, then the University shall, without prejudice to any other right or remedy, be at liberty to forfeit the said Earnest Money Deposit.
- 6. The time allowed for completing the work will be 30 (Thirty) days from the day of written order to commence the work.
- 7. Tenderer are advised to inspect and examine the site and its surroundings and satisfy themselves before submitting their tenders as to the nature of the ground and sub-soil (so far as is practicable), the form and nature of the site, the means of access to the site, the accommodation they may require and in general shall themselves obtain all necessary information as to risks, contingencies and other circumstances which may influence or affect their tender. A tenderer shall be deemed to have full knowledge of the site whether he inspects it or not and no extra charges consequent on any misunderstanding or otherwise shall be allowed. The tenderer shall be responsible for arranging and maintaining at his own cost all materials, tools & plants, water, electricity access, facilities for workers and all other services required for executing the work unless otherwise specifically provided for in the contract documents and has made himself aware of the scope and specifications of the work to be done



- and of conditions and rates at which stores, tools and plant, etc. will be issued to him by the University and local conditions and other factors having bearing on the execution of the work.
- 8. No Telex/ Tele fax/ Telegram/ E-mail of the Techno-Commercial and Price bids will be accepted. The University is not responsible for Postal. Courier delays. The parties have to ensure the receipt of bids well in time.
- 9. If the date of tender submission and opening happens to be unforeseen holiday, the same will be postponed to the next working day without any further intimation.
- 10. The University does not bind itself to accept lowest tender and reserves the right to reject any or all the tenders received by recording clear, logical reasons.
- 11. Canvassing whether directly or indirectly, in connection with tenders is strictly prohibited and the tender submitted by the contractors who resort to canvassing will be summarily rejected.
- 12. The competent authority on behalf of the University reserves to himself the right of accepting the whole or any part of the tender and the tenderer shall be bound to perform the same at the rate quoted.
- 13. This Notice Inviting Tender shall form a part of the contract document.
- 14. The successful tenderer/ contractor, on acceptance of his tender by the University, shall within 15 days from the stipulated date of start of the work sign the contract agreement in standard form consisting of the notice inviting tender, all the documents including additional conditions, specifications and drawings, if any, forming the tender as issued at the time of invitation of tender and acceptance thereof together with any correspondence leading thereto.
- 15. No materials will be supplied by the University.
- 16. In case of delay in completion of the work within the stipulated time due to reasons attributable to the contractor, Standard Liquidated Damage @ 1% of the tender accepted value shall be recovered for each day of delay from the final bill or the part there of.
- 17. The contractor shall obtain a valid license under the contract labour (R&A) Act, 1970, and the contract labour central rules 1971, before the commencement of the work, and continue to have a valid license until the completion of the work. The contractor shall also abide by the provisions of the Child Labour (Prohibition and Regulation) Act, 1986 and other labour laws. Any failure to fulfill this requirement shall attract the penal provisions of this contract arising out of the resultant no execution of the work. No labour below the age of eighteen years shall be employed on the work.
- 18. 18. The contractor should have valid Registration with all statutory authorities such as Central/ State Labour Dept, ESI, EPF, Service Tax etc.
- 19. During Opening of tender only representative duly authorized by the agency / contractor will be allowed to be present.
- 20. All relevant documents submitted with the tender should be self attested (by the agency/ contractor) and on demand original copy must be produced failing which tender will not be considered.
- 21. Authenticity of signatory (contractor) of tender document will be verified before finalization of tender document.



- 22. Tax at higher of prescribed rate or 20% will be deducted on all transactions liable to TDS, where the permanent Account Number (PAN) of the deducted is not available.
- 23. In case of any dispute, it would be referred to a sole Arbitrator to be appointed by the University authority. The decision of the sole Arbitrator will be final and binding to both the parties.
- 24. 10% security money will be retained by the University from the bill value which shall be released after 01(one) year of satisfactory completion of work.
- 25. EMD of unsuccessful bidder shall be released within 02 (two) months after issue of work order to the successful bidders.
- 26. If the work is found not as per specification or abandoned by the executing contractor/agency, same will be cancelled and remaining work will be done through other contractor/agency at their cost & risk.
- 27. Those bidders who accept the above terms and conditions, may submit their tender along with all relevant documents and a copy of above terms and conditions of the tender duly signed

Sd/ Executive Engineer



SECTION-2

PROFORMA - 2(a)

DETAILS OF CONTRACTOR'S REGISTRATION

1.	Name of Agency/ Contractor	:
2.	Name of the Department issued contractor's registration	n :
3.	Registration No	:
4.	Class of Registration	:
5.	Category of Registration	
6.	Valid Electrical License Registration No	:
7.	Tender limit	:
8.	Validity period	:
Coj	py of Registration certificate to be enclosed	Signature of Agency/ Contractor



PROFORMA - 2(c)

FORM OF SOLVENCY CERTIFICATE FROM A SCHEDULED BANK

This is to certify that to the best of our knowledge and information M/S/ Sri
This certificate is issued without any guarantee or responsibility on the Bank or any of the officers.
(Signature)
For the Bank
Note: In case of partnership firm, certificate to include names of all partners as recorded with the bank.
Signature of agency / contractor



$\underline{PROFORMA-3(a)}$

List of Similar nature of works executed during preceding 3 years under Central Govt. /State Govt. /Central PSU/ central autonomous body.

Sl.No	Name of work with brief particular thereof	Date of Commence ment	Date of Completion as per work order	Actual date of completion	Contract Amount (Rs)	Name of client, contact with his complete address Phone No.

Add extra sheet if requi

Sign of the company/Contractor

Date:

Note: Original or self-attested copies of work order & completion certificates from client shall be attached.



$\underline{PROFORMA-3(b)}$

3. B List of ongoing works:-

Sl.No	Name of work with brief particular thereof	Date of commencement	Date of completion as per work order	Contract Amount (Rs)	Name of client , contact with his complete address and Phone No.

Add	extra	sheet i	f rec	ıuired.

Seal & Signature of the company/Contractor

Date:

Note: Original or self-attested copies of work order from client shall be attached.



TENDER

I/We have read and examined the notice inviting tender, schedule, specifications applicable, General Rules and Directions, Conditions of contract and special conditions, schedule of rate and other documents and Rules referred to in the conditions of contract and all other contents in the tender document for the work.

I/We hereby tender for the execution of the work specified for AUS, Silchar within the time specified and in accordance in all respects with the specification, designs drawings and instructions in writing referred to in General Rule and Directions and in the conditions of contract and with such materials as are approved by the University Authority, and in respects in accordance with, such conditions so far as applicable.

I/We agree to keep the tender open for -----days from the due date of submission thereof and not make any modifications in its terms and conditions.

A sum of **Rs. 12,500/-** is hereby forwarded in FDR/ Call deposit in favour of Assam University, Silchar of scheduled Bank as earnest money. If I/We, fall to commence the work specified I/We agree that the A.U. Silchar or his authorizes officer successors in office shall without prejudice to any other right or remedy, be at liberty to forfeit the said earnest money absolutely otherwise the said earnest money shall be retained by him towards security deposit to execute all the works referred to therein and to carry out such deviations as may or orders, up to maximum of the percentage mentioned in the conditions of contract and those in excess of limit at the rates to be determined in accordance with the provision mentioned in the tender form.

I/We agree that should I/We fall to commence the work specified in the above memorandum, an amount equal to the amount of the earnest money mentioned in the form of the invitation of tender shall absolutely be forfeited to the Silchar and the same may be the option of the competent authority on behalf of the A.U. Silchar be recovered without prejudice to any other right or remedy available in law out of the deposit in so far as the same may extend in terms of the said bond and in the event of deficiency out of any other money due to me/ us under this contract or otherwise.

Date :- Signature of Contractor

Postal Address & Tele No.



SECTION –3

GENERAL RULES AND DIRECTIONS

1. SUBMISSION OF TENDER

- (a) The General Conditions of Contract for Central PWD /APWD Works shall be the guiding principles for this work. Tenderers are advised to procure the same and familiarize themselves with the provisions of the above mentioned Conditions of Contract.
- (b) The University reserves the right to alter, modify any Tender Conditions, technical specifications etc., before tender opening and may seek fresh quotation depending upon necessity, and may even withdraw/ cancel the tender, without assigning any reason.
- (c) All amendments/ revisions to tender documents issued by the University, if any, must be signed and submitted along with the tender. The tenderers are advised to submit the tender based strictly on the terms and conditions and specifications contained in the tender documents, and not to stipulate any deviations.
- - b) Insertion, postscript, addition and alteration shall not be recognized unless confirmed by the Tender's signature.

In the event of the tender being submitted by a firm, it must be signed separately by each partner thereof or in the event of the absence of any partner, it must be signed on his behalf by a person holding a power of attorney.

3. TENDERER TO INFORM HIMSELF FULLY:

The tenderer is required to carefully examine the technical specifications and other details relating to the work given in the Tender documents and fully inform himself as to all conditions and matters that may in any effect the work or the cost thereof. The tender shall be deemed to have himself independently obtained all necessary information for the purpose of preparing the tender and his tender as accepted shall be deemed to have taken into account all contingencies as may arise due to such information or lack of the same.



PARTICULARS OF TENDER:

Last Date and Place of Tender Submission : Engineering Section, Assam University,

Silchar by 21.12.2017 up to 2.00 P.M.

Date and Place of opening of Technical Bid : Engineering Section, Assam University,

Silchar on 21.12.2017 at 3.00 P.M

Validity of tender: Tender shall remain valid for acceptance for a period of not less than 90 days

from the date of opening of tenders which may be required to be extended in

public interest at the discretion of the University Authority.

CLARIFICATIONS:

The Tender Document issued is complete in all respect and no further clarifications are elaborated. However, in so far Technical Clarifications if any are concerned even though not binding on University can be ascertained from the University.

QUOTATION OF PRICE / RATES

This being Item Rate Tender, the tenderer shall state at what rate he will be willing to undertake the work. Rate should be quoted both in figure &words.

COMPLETION TIME:

The completion time is the essence of the contract. The Tenderer shall complete the work within the period indicated in the Notice Inviting Tender.

TRANSFER OF TENDER DOCUMENTS/ TENDERS:

Transfer of tender documents purchased by one tenderer to another is not permissible. Similarly transfer of tenders submitted by one tenderer to another is not permissible under any circumstances. The alteration of essence of tender once submitted is also not permissible.

LANGUAGE:

The Tender shall be submitted in English language only.



EARNEST MONEY DEPOSIT:

- 1. The tender must be accompanied by the Earnest Money Deposit pledged in favor of **Assam University, Silchar**, in the form of Demand Draft / FDR/Call Deposit as indicated in the Notice Inviting Tender. If the tenderer after submitting his tender release from his offer or modify the Terms and Conditions thereof in a manner not acceptable to the University, the Earnest Money will be forfeited. Tenders not accompanied by the earnest money deposit will not be considered and will be summarily rejected.
- 2. On Non-acceptance of tender, but in any case not earlier than the expiry date of the period for which the tender is kept open, the Earnest Money shall be discharged.
- 3. Should the Tender in question be withdrawn or cancelled by the University, which the University shall have the right to do at any time, Earnest Money will be discharged.
- 4. Should the successful tenderer fail or refuse to duly sign the contract within the period fixed by the University or fail/refuse to commence the work within the stipulated time, the Earnest Money shall be forfeited without prejudice to his being liable for any further loss or damage incurred in consequence by the University.

NO CLAIM FOR COMPENSATION FOR SUBMISSION OF TENDER:

The Tenderer whose tender is not accepted shall not be entitled to claim any costs, charges and expenses of any incidental to or incurred by him thorough or in connection with his submission of tender, even though the University may modify/ withdraw the Tender.

LOWEST TENDER NOT NECESSARILY TO BE ACCEPTED:

The University does not bind itself to accept lowest tender and reserves the right to reject any or all the tenders received by recording clear, logical reasons.

TENDER EVALUATION:

The Tenders received and accepted will be evaluated to ascertain the best and lowest workable tender in the interest of the University, for the complete work covered under the technical specifications and documents.



SECTION – 4

TERMS AND CONDITIONS GOVERNING THE TENDER AND EXECUTIONOF CONTRACT THEREOF.

1.DEFINITIONS:

a) Unless otherwise required by the subject or context the terms herein below shall have the following meanings.

The **Contract** means the documents forming the tender and acceptance thereof and the formal agreement executed between the competent authority on behalf of Assam University and the Contract, together with the documents referred to therein including these conditions, the specifications, designs, drawings and instructions issued from time to time by the Registrar, Assam University and all the these documents taken together, shall be deemed to form one contract and shall be complementary to one another.

- b) Client means Assam University acting through The Executive Engineer Assam University, Silchar.
- c) The **Contractor** shall mean the individual, firm or company, whether incorporated or not, undertaking the works and shall include the legal personal representative of such individual or the persons composing such firm or company, or the successors of such firm or company and the permitted assigns of such individual, firm or company,
- **d**)The expression **works** or **work** shall, unless there be something either in the subject or context repugnant to such construction, be construed and taken to mean the works by or by virtue of the contract contracted to be executed whether temporary or permanent, and whether original, altered, substituted or additional.
- e) The **site** shall mean the land/ or other places, on, into or through which work is to be executed under the contract or any adjacent land, path or street which may be allotted or used for the purpose of carrying out the contract.
- f) Tender Value means the value of the entire work as stipulated in the letter of award.
- **g)** Where the context so requires, words imparting the singular only also include the plural and vice versa. Any reference to masculine gender shall whenever required include feminine gender and vice versa.
- **h**) As stated in Section III, Clause 1.1, the General Conditions of Contract for Central PWD Works shall be the guiding principles for this tender. The Clauses of Contract mentioned therein shall also be applicable herein and only those Clauses that need addition, emphasis and modification in context of this tender are enumerated below. Contractors are once again advised to familiarize themselves with the General Conditions of Contract for Central PWD Works.



2.SIGNING OF CONTRACT AGREEMENT

- i. On the tender being accepted by the Client, a formal contract may be signed and executed by and between the Client and the successful tendered within a time to be fixed by the Client, which shall anyhow be within 15 days from the stipulated date of start of the work.
- ii. The contractor shall be furnished, free of cost one certified copy of the contract documents except standard specifications, Schedule of Rates and such other printed and published documents, together with all drawings as may be forming part of the tender papers. None of these documents shall be used for any purpose other than that of this contract.

3. SCOPE OF WORK

- i. The work to be carried out under the Contract shall, except as otherwise provided in these conditions, include all labor, materials, tools, plants, equipment and transport which may be required in preparation of and for and in the full and entire execution and completion of the works. The descriptions given in the Schedule of Quantities shall, unless otherwise stated, be held to include wastage on materials, carriage and cartage, carrying and return of empties, hoisting, setting, fitting and fixing in position and all other labours necessary in and for the full and entire execution and completion of the work as aforesaid in accordance with food practice and recognized principles.
- ii. The contractor shall be deemed to have satisfied himself before tendering as to the correctness and sufficiency of his tender for the works and of the rates and prices quoted in price bid which rates and prices shall, except as otherwise provided, cover all his obligations under the Contract and all matters and things necessary for the proper completion and maintenance of the works.

4. DISCREPANCIES AND ADJUSTMENT OF ERRORS

- i. The several documents forming the Contract are to be taken as mutually explanatory of one another, detailed drawings being followed in preference to small scale e drawing and figured dimensions in preference to scale and special conditions in preference to General Conditions.
- ii. If there are varying or conflicting provisions made in any one document forming part of the contract, the Registrar, Assam University shall be the deciding authority with regard to the intention/interpretation of the document and his decision shall be final and binding on the contractor.
- iii. Any error in description, quantity or rate in Schedule of Quantities or any omission there from shall not vitiate the contract or release the Contractor from the execution of the whole or any part of the works comprised therein according to drawings and specifications or from any of his obligations under the contracts.



5. TERMS OF PAYMENT

Subject to any deduction, which the client may be entitled to make under the Contract, all payments to contactor for the work would be made by Cheque / Demand Draft in favour of the contractor on satisfactory completion report of Site (i/c) of the proposed work.

6. SECURITY DEPOSIT

10% Security Deposit will be retained by the University from the bill value, which shall be released after one year from the date of completion of the work. During this defect liability period, any defect(s) in the work done shall be rectified by the Contractor at his/her own cost and expenses, failing which the Security Deposit will be forfeited.

7. RELEASE OF SECURITY DEPOSIT

Release of the security deposit will be done after 01 year of final acceptance of the work by the Assam University, Silchar.

8. SUB CONTRACTING OF THE WORK

The Contractor is not permitted to assign or transfer his/ their obligation or benefit under the contract either in full or in part to other individuals/ firms / agencies. However, under extreme circumstances where sub-contracting of part of the work is unavoidable, prior written permission of Client shall be taken by the Contractor.



Price Bid

Name of Work: -- 1) Erecting of New LT line for Widening of the Campus Main Road & Dismantling of the Existing MS Poles & LT Lines. 2) Extension Admin LT line to Existing Generator Room. 3) Rearrangement of LT line for Health Center, UN Brahma Auditorium & Foreign Hostel to nearest 250 KVA Transformer.

<u>Estimated Cost</u> - **6,20,056**/-



PRICE BID

- 1) Erecting of New LT line for Widening of the Campus Main Road & Dismantling of the Existing MS Poles & LT Lines. 2) Extension Admin LT line to Existing Generator Room.
- 3) Rearrangement of LT line for Health Center, UN Brahma Auditorium & Foreign Hostel to nearest 250 KVA Transformer.

SL No	Item Description	Qnty	UOM	Unit Rate	Amount
1	Supplying and erection PSC pole 8.5 metre long, the pole is to be erection in 1:2:3 plain cement concrete foundation of size 1.50 m x 0.45 m x 0.45m having P.C.C base foundation 15 cm x 60 cm x 60cm including edge brick soiling and plastering above G.L. portion (0.30 metre complete with excavation of earth, handling of Surplus Soil, debris etc. to the proper place and refilling etc. as specified and as directed by the department.	10	Each		
2	Supplying and erection of L.T. stay set complete (Galvanize with 19mm dia x1.8m long stay rod anchor plate of size 30cm x 30cm x 6.4 mm thimble stay clamps tube buckle (19mmx 60c 7/14 SWG dia G.I stay and strain insulation etc. in cement concrete 1:3:6:(1Cement:3Course sand:6graded stone aggregate 40mm nominal size foundation including excavation and refilling etc. as required and as directed by the department.	7	Each		
3	Supplying and erection of L.T. Pin insulators with G.I. pin complete with blots and nuts coach screw etc. as required and as directed by the department.	52	Each		
4	Supplying and erection of L.T. Shackle insulators with shackle strap complete with blots and nuts coach screw etc. as required and as directed by the department.	56	Each		



5	Supplying and string up AAAC Rabbit conductor in the existing P.S.C./ M.S/ Galvanized pole with binding etc. as required and as directed by the department.	1280	Metre.	
6	Supplying and fitting fixing of H.T. danger plate complete as required and as directed by the department.	2	Each	
7	Dismanteling of existing LT poles and existing LT line from main gate to student council and as directed by department	33	Each	
	Unskilled lablor 2 nos @ Rs 359 / pole and LT dismanteling @ Rs.100/ span			
8	LT MS 80 cm X 5 cmX 4 mm thick channel with required MS clamps and required nuts & bolts as directed by deptt.	20	Each	
9	Supply, installation & testing of G.I. Plate earth station with 600 mmx600 mmx6 mm heavy duty G.I. earth plate with necessary 40 mm dia. G.I. watering pipe with G.I. Fittings such as Socket, Tee, elbow, nipple and 50 mmx40 mm G.I. reducing socket for funnel including locking arrangement with 300 mmx300 mmx6 mm hinged cover C.I. cover plate complete with digging of earth pit, construction of brick chamber and plastering of both inner & outer surface of wall as specified and directed by the deptt	1	Each	
10	Supplying & laying of 8 SWG G.I. earth from Earth Electrode (below G.L.) to electrical switch gears or electrical machineries including making necessary connection as approved, specified and directed by the deptt.	30	Metre.	
				Total
	Extension Admin LT line to Supplying and erection PSC pole 8.5	existing (Generator 1	room
1	metre long, the pole is to be erection in 1:2:3 plain cement concrete foundation of size 1.50 m x 0.45 m x 0.45m having P.C.C base foundation 15 cm x 60 cm x 60cm including edge brick soiling and	5	Each	



	plastering above G.L. portion (0.30 metre			
	complete with excavation of earth,			
	handling of Surplus Soil, debris etc. to the			
	proper place and refilling etc. as specified			
	and as directed by the department.			
	Supplying and erection of L.T. stay set			
	complete (Galvanize with 19mm dia			
	x1.8m long stay rod anchor plate of size			
	30cm x 30cm x 6.4 mm thimble stay			
	clamps tube buckle (19mmx 60c 7/14			
2	SWG dia G.I stay and strain insulation etc.	3	Each	
2	in cement concrete	3	Each	
	1:3:6:(1Cement:3Course sand:6graded			
	stone aggregate 40mm nominal size			
	foundation including excavation and			
	refilling etc. as required and as directed by			
	the department.			
	Supplying and erection of L.T. Pin			
	insulators with G.I. pin complete with			
3		64	Each	
3	blots and nuts coach screw etc. as required	04	Lacii	
	and as directed by the department.			
	Supplying and erection of L.T. Shackle			
	insulators with shackle strap complete			
	with blots and nuts coach screw etc. as			
4		16	Each	
	required and as directed by the			
	department.			
	Supplying and string up AAAC Rabbit			
	conductor in the existing P.S.C./ M.S/			
5	Galvanized pole with binding etc. as	720	Metre.	
	required and as directed by the			
	department.			
	Cymplying and fitting fining of HT			
	Supplying and fitting fixing of H.T.			
6	danger plate complete as required and as	2	Each	
	directed by the department.			
	Supply and laying of following size			
	PVC/XLPE insulated and PVC sheathed			
	1.1 KV G Solid Aluminium conductor up			
	to 10 sq mm balance stranded conductor,			
	XLPE Insulated, cores laid up, PVC tape			
7	inner sheathed, Armour (Aluminium for			
	single core up to 70 sq mm balance			
	Aluminium strip, Galvanised for cables up			
	to 2x10 sq mm.3x10 sq mm,4x6 sq mm			
	balance all galvanised steel strip),			
	extruded PVC Type ST2 sheathed,			
	650/1100V grade as per IS 7908(Part 1)			



	1	ı	1	1	I		
	1988 armoured U.G. cable U.G. cable						
	laid in ground/partially in air (as required						
	for termination over ground including						
	excavation of cable trench up to depth of						
	75cm, refilling, protective brick covering,						
	Sand cushioning etc complete handling of						
	surplus spoil, debris et to proper place as						
	specified and directed by the deptt.						
	(Nicco/ Havells/						
	RPG/CCI/Polycab/Gloster/ Finolex make)						
	185.00 Sq. mm.3 & 1/2 Core armoured						
	U.G. cable	25	Metre				
	U.G. cable						
	240.00 Sq. mm.3 & 1/2 Core armoured	25	34.				
	U.G. cable	25	Metre				
	Supply, installation & testing of G.I. Plate						
	earth station with 600 mmx600 mmx6						
	mm heavy duty G.I. earth plate with						
	necessary 40 mm dia. G.I. watering pipe						
	with G.I. Fittings such as Socket, Tee,						
	elbow, nipple and 50 mmx40 mm G.I.						
8	reducing socket for funnel including	1	Each				
	locking arrangement with 300 mmx300						
	mmx6 mm hinged cover C.I. cover plate						
	complete with digging of earth pit,						
	construction of brick chamber and						
	plastering of both inner & outer surface of						
	wall as specified and directed by the deptt						
	Supplying & laying of 8 SWG G.I. earth						
	from Earth Electrode (below G.L.) to						
9	electrical switch gears or electrical	30	Metre.				
	machineries including making necessary						
	connection as approved, specified and						
	directed by the deptt.						
	LT MS channel with required MS clamps	10					
	and required nuts & bolts	10					
			Sub	Total			
Rear	Rearrangement of LT Line for Health Center, UN Brahma Auditorium & Foreign Hostel to						
	nearest 250 KVA Transformer.						
	Supplying and erection PSC pole 8.5						
	metre long, the pole is to be erection in						
	1:2:3 plain cement concrete foundation of						
1	size 1.50 m x 0.45 m x 0.45m having	8	Each				
1	P.C.C base foundation 15 cm x 60 cm x	0	Eacil				
	60cm including edge brick soiling and						
	plastering above G.L. portion (0.30 metre						
	complete with excavation of earth,						
L	<u> </u>	1	1	1	ı		



	handling of Surplus Soil, debris etc. to the			
	proper place and refilling etc. as specified and as directed by the department.			
2	Supplying and erection of L.T. stay set complete (Galvanize with 19mm dia x1.8m long stay rod anchor plate of size 30cm x 30cm x 6.4 mm thimble stay clamps tube buckle (19mmx 60c 7/14 SWG dia G.I stay and strain insulation etc. in cement concrete 1:3:6:(1Cement:3Course sand:6graded stone aggregate 40mm nominal size foundation including excavation and refilling etc. as required and as directed by the department.	5	Each	
3	Supplying and erection of L.T. Pin insulators with G.I. pin complete with blots and nuts coach screw etc. as required and as directed by the department.	32	Each	
4	Supplying and erection of L.T. Shackle insulators with shackle strap complete with blots and nuts coach screw etc. as required and as directed by the department.	60	Each	
5	Supplying and string up AAAC Rabbit conductor in the existing P.S.C./ M.S/ Galvanized pole with binding etc. as required and as directed by the department.	360	Metre.	
6	Supplying and fitting fixing of H.T. danger plate complete as required and as directed by the department.	2	Each	
7	Supply and laying of following size PVC/XLPE insulated and PVC sheathed 1.1 KV G Solid Aluminium conductor up to 10 sq mm balance stranded conductor, XLPE Insulated, cores laid up, PVC tape inner sheathed, Armour (Aluminium for single core up to 70 sq mm balance Aluminium strip, Galvanised for cables up to 2x10 sq mm.3x10 sq mm,4x6 sq mm balance all galvanised steel strip), extruded PVC Type ST2 sheathed, 650/1100V grade as per IS 7908(Part 1) 1988 armoured U.G. cable U.G. cable laid in ground/partially in air (as required			



	for termination over ground including excavation of cable trench up to depth of 75cm, refilling, protective brick covering, Sand cushioning etc complete handling of surplus spoil, debris et to proper place as specified and directed by the deptt. (Nicco/ Havells/ RPG/CCI/Polycab/Gloster/ Finolex make)			
	35.00 Sq. mm.3 & 1/2 Core armoured U.G. cable	10	Metre	
	70.00 Sq. mm.3 & 1/2 Core armoured U.G. cable	10	Metre	
8	Supply including fitting and fixing of Resin Cast type 1.1 KV PVC/XLPE/PILC cable Straight through Jointing Kits (MS - SE AL make) including all accessories for the following sizes including testing and commissioning as specified and directed by the Deptt.			
	70.00 Sq.mm., 3.5 Core cable.	2	Each/Set	
9	Supplying & laying of 8 SWG G.I. earth from Earth Electrode (below G.L.) to electrical switch gears or electrical machineries including making necessary connection as approved, specified and directed by the deptt.	1	Metre.	
10	Supplying including installation, commissioning of vermin and dust proof totally enclosed cubical indoor type floor/wall mounting compartmentalize panel board of size 1.25M X0.6MX 0.40M made of 16 SWG/1.66 mm thick C.R. sheet and 35mm X 35mm X 5mm size angle having 4 no legs at the bottom complete painting with 2 coats of Red Oxide metal primer and 2 coats of Enamel paint. The panel board is to be erected in 1:3:6 PCC foundation and brick soling / grouting etc. complete neatly Wiring done with provision for one no 125/160A 4pole MCCB or Switch Fuse Unit as incomer and provision for 2nos DP or TPN out going as specified and directed by the deptt. confirming to IP 43 protection comprising of the following electrical			



	items:				
	1. 20mm X 3mm 4 strip copper Bus-Bar 0.5M length each				
	2. Digital 3 Phase Voltmeter Accuracy class 0.5 - 1 no				
	3. Digital 3 Phase Ammeter Accuracy class 0.5 - 1 no				
	4. Pilot Lamp with integral ckt LED 110-230 V (Red, Yellow,& Blue - 3 no				
	5. Voltmeter & Ammeter Selector Switch - 2 no				
	6. 2 A Slide fuse unit - 3nos				
	(Incoming & Outgoing Switch Gear of reqd. rating will be measured and paid separately)	1	Each		
11	Supplying with fitting and fixing panel mounting open execution 25 KA 415V 50Hz 3P MCCB (Ics=Icu, adjustable Ir setting 0.7) without enclosure of the following capacity complete with making necessary connection as approved by the Deptt. as specified and directed by the deptt.				
	25 KA 415V 50 Hz 3P MCCB (Schneider, legrand, Siemens make)				
	63A	2	Each	_	
	100A	1	Each		
12	LT MS channel with required MS clamps and required nuts & bolts	20	Each		
			Sub Tota	ıl	

Total Amount =	
Total Amount (In words) =	
	Name:-
	Address:-
	Ph No:-